



Model: CHWDT

Model: CHWDT





Table of Contents

Product Image	1
Table of Contents	2
What is a Programmable Room Thermostat?	
Installation Procedure	5-6
LCD Display	7-8
Setting the Clock	9
Temperature Display	10
Programming	11-12
Locking the Thermostat	13
Temperature Control	14
Temperature Hold	15
Holiday Programming	16
Frost Mode	17
Heating On / Off	18
Optional Features	19-22
Re-calibrating the Thermostat	23
Factory Reset	24
Error Codes	25
Wiring Diagrams	26-28



What is a Programmable Room Thermostat?

A programmable room thermostat is both a programmer and a room thermostat.

The programmer allows you to set "On" and "Off" periods to suit your own lifestyle. The room thermostat works by sensing the air temperature, switching on the heating when the air temperature falls below the thermostat setting, and switching it off once this set temperature has been reached.

So a programmable room thermostat lets you choose what times you want the heating to be on, and what temperature it should reach while it is on. It will allow you to select different temperatures in your home at different times of the day (and days of the week) to meet your particular needs and preferences.

Setting a programmable room thermostat to a higher temperature will not make the room heat up any faster. How quickly the room heats up depends on the design & size of the heating system.

Similarly reducing the temperature setting does not affect how quickly the room cools down. Setting a programmable room thermostat to a lower temperature will result in the room being controlled at a lower temperature, and saves energy.

The way to set and use your programmable room thermostat is to find the lowest temperature settings that you are comfortable with at the different times you have chosen, and then leave it alone to do its job.

The best way to do this is to set the room thermostat to a low temperature – say 18°C , and then turn it up by 1°C each day until you are comfortable with the temperature. You won't have to adjust the thermostat further. Any adjustment above this setting will waste energy and cost you more money.

If your heating system is a boiler with radiators, there will usually be only one programmable room thermostat to control the whole house. But you can have different temperatures in individual rooms by installing thermostatic radiator valves (TRVs) on individual radiators.

If you don't have TRVs, you should choose a temperature that is reasonable for the whole house. If you do have TRVs, you can choose a slightly higher setting to make sure that even the coldest room is comfortable, then prevent any overheating in other rooms by adjusting the TRVs.

You are able to temporarily adjust the heating program by overriding or using the temperature hold feature. These features are explained further on pages 14 and 15 of this manual.

Programmable room thermostats need a free flow of air to sense the temperature, so they must not be covered by curtains or blocked by furniture. Nearby electric fires, televisions, wall or table lamps may also prevent the thermostat from working properly.



Installation Procedure



Do

Mount the thermostat at eye level. Read the instructions fully so you get the best from our product.



Don't

Do not install near to a direct heat source as this will affect functionality. Do not push hard on the LCD screen as this may cause irreparable damage.

This Slimline Series thermostat is designed to be flush mounted and requires a back box of 35mm (minimum depth) to be sunk into the wall prior to installation.

Step 1

Carefully separate the front half of the thermostat from the back plate by placing a small flat head terminal driver into the slots on the bottom face of the thermostat.

Step 2

Place the thermostat front somewhere safe.

Terminate the thermostat as shown in the diagrams on pages 25-27 of this booklet.

Step 3

Screw the thermostat back plate securely into the back box.

Step 4


Clip the front of the thermostat back onto the thermostat back plate.











LCD Display

- 1. Room/Floor Temp Indicates the current temperature sensor mode.
- 2. Day Indicator Displays the current day.
- 3. Frost Icon Displayed when the thermostat is in frost protection mode.
- Flame Icon Displayed when the thermostat is calling for heat, the flame icon will flash when the optimum start function is in operation.
- Floor Temp Limit Icon Displayed when the floor sensor probe has reached the upper and lower temperature limits set in features 09 & 10.
- Temperature Hold When a Temp Hold is active, HOLD FOR and the remaining time period is displayed.
- Set Indicates when changes are being made to programs or temperature set points.
- 8. Holiday Indicator Displayed when the thermostat is in holiday mode.
- 9. Current Temp Indicates the current sensor temperature.
- Program Cycle Indicator Displayed during programming only to show which period is being altered.
- 11. Keypad Lock Indicator Displayed when the keypad is locked.
- 12. Units of Temperature Degrees Celsius or Fahrenheit.
- 13. Clock Digital clock display in 24h format.




Setting the Clock

To set the clock, follow these steps.

- Use the Up/Down keys to set the hours


 Press H to confirm settings




Temperature Display

The temperature display information is driven by two different inputs; the sensor measurement and the target temperature you have set.







This is the temperature you are trying to achieve in your home.

Programming

The thermostat provides Weekday/Weekend or 7 Day Programming options. You should consult the "Optional Features" section to select the required mode.

The thermostat is supplied with comfort levels already programmed, but these can be changed easily. The default times and temperatures are;

 $08.00 - 21^{\circ}$ C (Wake) $09.30 - 16^{\circ}$ C (Leave) $16.30 - 22^{\circ}$ C (Return) $23.00 - 17^{\circ}$ C (Sleep) If you only want to use 2 levels, you should program the unused levels to ----

Note: For Weekday/Weekend programming, the 4 comfort levels are the same for all weekdays but can be different for the weekends.

For 7 Day programming, each day can have 4 different comfort levels.

To program comfort levels, press Clock once



For Weekday/Weekend programming, Mon Tue Wed Thu Fri are displayed on screen.



For 7 Day programming, only Mon is displayed in the day indicator field.

- You will now see "LEAVE" displayed on screen.
- Repeat the programming steps for each period until complete.
- · For unused periods enter --.-- and the thermostat will ignore the setting.

Press H to confirm settings

Note:

- In 7 Day programming mode you can repeat for each day independently.
- In Weekday/Weekend programming mode you will see Sat Sun displayed on

Н




Locking the Thermostat

The thermostat has a keypad lock facility. To activate the lock follow these steps.

- Press and hold the A and Down keys together for 10 seconds A ▼
- You will see the lock symbol appear on screen
 To unlock, repeat the steps above until the lock symbol disappears.


Note: The keypad lock indicator is only displayed when the lock is active.





Temperature Control

 $Note: This\ override\ will\ be\ maintained\ until\ the\ next\ programmed\ comfort\ level.$






Temperature Hold

The temperature hold function allows you to manually override the current operating program and set a different temperature for a desired period.

- Press H to confirm settings
 Use the Up/Down keys to enter the required Hold temperature......

You will see the Hold For indication is displayed on screen.

The time will countdown the set duration and then revert to the normal program.



To cancel temperature hold, follow the same steps but reduce the Hold time to 00:00 hours.




The holiday function reduces the set temperature in your home to the frost protection temperature setting (see page 19).

The thermostat will maintain this temperature for the duration of the holiday and will then automatically return to the program mode on your return.

- The display will show a suitcase indicating the thermostat is in holiday mode.


Note: A holiday pariod does not start until 00:00 the payt day. For example, if w

Note: A holiday period does not start until 00:00 the next day. For example, if you set a holiday period on Friday for 2 days, Saturday will be counted as the first day and the thermostat will revert back to the programmed schedule at 00:00 on Monday.



To cancel, follow the same steps but reduce the Holiday duration to 00 days.

Frost Mode





Heating On/Off

The heating is indicated ON when the flame icon is displayed.

When the flame icon is absent, there is no requirement for heating to achieve the set temperature but the thermostat remains active.

To turn the thermostat back ON, press the Power button once again



Thermostat completely OFF



Thermostat powered ON



^{*}See Feature 3 on page 19



THE FOLLOWING SETTINGS ARE OPTIONAL AND IN MOST CASES NEED NOT BE ADJUSTED

Feature 01 - Temperature Format: This function allows you to select between °C and °F.

Feature 02 – Switching Differential: This function allows you to increase the switching differential of the thermostat. The default is 1°C which means that with a set temperature of 20°C, the thermostat will switch the heating on at 19°C and off at 20°C.

With a 2°C differential, the heating will switch on at 18°C and off at 20°C.

Feature 03 – Frost Protect: You can set whether the thermostat will maintain the frost temperature when the thermostat display is turned off. As a default, this is enabled.

Feature 04 – Frost Protect Temperature: This is the temperature maintained when the thermostat is in frost mode. The range is 07 - 17°C. The default is 12°C and is suitable for most applications.

Feature 05 – Output Delay: To prevent rapid switching, an output delay can be entered. This can be set from 00 - 15 minutes. The default is 00 which means there is no delay.

Feature 06 - Communication Address: Not used on this model.

Feature 07 – Temperature Up/Down Limit: This function allows you to limit the use of the up and down keys. This limit is also applicable when the thermostat is locked and so allows you to give others limited control over the heating system.

Feature 08 – Sensor Selection: On this thermostat, you can select which sensor should be used. You can choose between air temperature only, floor temperature or air and floor. When you enable both sensors, the floor sensor is used as a floor limiting sensor and is designed to prevent the floor from overheating.

In addition you also have a minimum floor temperature setting. Once the floor temperature drops 1 whole degree below the pre-set target, the thermostat will demand heat to maintain it the minimum set level (Feature 09).

Note: This model MUST NOT be used to control electric underfloor heating.

Feature 09 – Minimum Floor Temperature: This function is available when feature 08 is set to 02. You can set a floor minimum temperature between 05-24°C. (24°C is the default).

Feature 10 – Floor Temp Limit: This function is available when feature 08 is set to 02. You can set a floor limiting temperature between 26-36°C. (30°C is the default).

Feature 11 – Optimum Start: Optimum start will delay the start-up of the heating system to the latest possible moment to avoid unnecessary heating and ensure the building is warm at the programmed time. The thermostat uses the rate of change information to calculate how long the heating needs to raise the building temperature 1°C (with a rate of change of 20, the thermostat has calculated the heating needs 20 minutes to raise the building temperature 1°C) and starts the heating accordingly.

Feature 12 – Rate of Change: This is the number of minutes the thermostat has calculated it takes to raise your building temperature 1°C. The thermostat will continue to monitor and learn the heat up time of your home to optimise heating efficiency.


Feature 13 - Programming Mode: The thermostat offers 2 programming methods. Weekday/Weekend allows you to program 4 comfort levels for the weekdays and 4 different comfort levels for the weekend. In 7 Day program mode, each day as 4 comfort levels that can be programmed independently.



Adjusting the Optional Settings

To adjust the optional settings, follow these steps.

- Press and hold the Power button to turn the thermostat OFF



- Use the Clock key to cycle through the features
 Use the Up/Down keys to change the setting
- Press the Power button once again to turn the thermostat back ON



Optional Settings - Feature Table


FEATURE	DESCRIPTION	SETTING
01	Temperature Format	$00 = {^{\circ}C}, 01 = {^{\circ}F} ({^{\circ}C} = Default)$
02	Switching Differential	$01^{\circ} - 03^{\circ}C$ ($01^{\circ}C = Default$)
03	Frost Mode	00 = Enabled, 01 = Disabled (00 = Default)
04	Frost Protection Temperature	$07^{\circ} - 17^{\circ}C (12^{\circ}C = Default)$
05	Output Delay	00 - 15 Minutes (00 = Default)
06	Communications ID No.	Not used on this model
07	Up/Down Temperature Limit	00° - 10°C (00 = Default)
08	Sensor Selection	00 = Air Sensor Only 01 = Remote Floor Sensor 02 = Air & Floor Sensor
09	Minimum Floor Temperature	05° - 24°C (24°C = Default)
10	Floor Temperature Limit	26° - 36°C (30°C = Default)
11	Optimum Start	00 - 03 Hours (00 = Default)
12	Rate of Change	Minutes to raise by 1°C
13	Program Mode	00 = Non Programmable 01 = Weekday/Weekend 02 = 7 Day Programming



Re-calibrating the Thermostat

If you need to re-calibrate the thermostat, follow these steps.

- Press and hold the Power button to turn the thermostat OFF
- Press and hold BOTH the Power and Down keys together until the temperature appears and flashes twice before releasing
- Use the Up/Down keys to configure the new temperature
- Press A to confirm settings Press the Power button once to turn the thermostat back ON





The thermostat has a reset function to restore all settings to their factory defaults.

To perform a factory reset, follow these steps.

- When the icons have disappeared from the screen, the thermostat has been successfully reset.
- Press the Power button once to turn the thermostat back ON

All icons displayed simultaneously.




Factory reset is complete.



E0 = The internal sensor has developed a fault. You should contact your thermostat retailer for assistance.

E1 = The remote floor probe has not been connected, has been wired incorrectly or the probe is faulty.


E2 = The remote air probe has not been connected, has been wired incorrectly or the probe is faulty.





Wiring Diagram - CHWDT to Boiler S/L


THIS UNIT MUST BE PROTECTED BY A FUSE OR RCD





Wiring Diagram - CHWDT to Boiler Voltfree

THIS UNIT MUST BE PROTECTED BY A FUSE OR RCD




LS & LR ARE NORMALLY THE ROOM THERMOSTAT CONNECTIONS



Wiring Diagram - CHWDT to Valve

THIS UNIT MUST BE PROTECTED BY A FUSE OR RCD





Notes	



Want More Information?

Central Heating New Zealand Ltd 52 Pilkington Way, Christchurch Ph: 0800 3571233

info@centralheating.co.nz www.centralheating.co.nz

